

From: Assistant Divisional Fire Officer/Fire Station Officer
Rewari

To: M/s AASTHA PUBLIC SCHOOL
VILLAGE BASDUDA REWARI

Memo No. FS/2023/47 dated : 06/11/2023

Subject: Renewal of Fire Safety Certificate Under 15 mtrs. height from the fire Safety Point of View of the Group B-Educational Building at VILLAGE BASDUDA REWARI of AASTHA PUBLIC SCHOOL :

Reference to you online No 150892323000282 dated 10/10/2023 on the subject cited above.

Tower Name	Floor Detail	Height	Ground Coverage
	GROUND-I FLOOR	06 M	1290.157 Sqm
Basement Level	Basement Area	Remarks	
0	0	0	

A site for the Renewal of the Fire Safety Certificate has been inspected by the Team of Fire Station Officers, Rewari from the Fire Safety Point of View. The means of escape and fire protection systems were checked and found to be in compliance with the Building Code of India, Part IV guidelines.

In view of the satisfactory fire protection system, arrangement made in this office has no objection to the occupation from the Fire Safety point of view, with the following conditions:

- 1) The owner/occupier shall keep duly trained Fire Staff in all three shifts.
- 2) The Fire Protection System tested during inspection shall be maintained properly & always should be in good working condition.
- 3) If any lapse is found in the fire protection system at the time of inspection or detected during outbreak of fire action shall be taken as per rules against you.
- 4) You are directed to apply for Renewal of Fire Safety Certificate in future before 2 month of expiry of your Fire Safety Certificate.
- 5) If the owner set back area is not checked at our end as it shall be checked by concerned building department.
- 6) The owner/occupier shall strictly follow the other applicable rules/regulations/byelaws laid down regarding fire safety. If you fail to comply with any of the above terms & conditions you will be liable to be punished as per Section 47 of fire & Emergency Services Act 2022.
- 7) You have to perform quarterly Fire Drill in your building as per NBC with intimation to Fire Department. The evidence to be kept as a record which shall be produced at the time of next Renewal; Officials/Residents/RWA should be mentioned in the drill.
- 8) If the Infringements of Byelaws remains un-noticed the Authority reserves the right to amend the Fire Safety Certificate as and when any such Infringements comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.
- 9) The owner or occupier of the building shall give a self-declaration certificate annually to the effect that the fire protection system installed in his building is working in good condition and there is no addition/alteration in the building. The Fire Officer may randomly check such building. In case there is any addition/alteration beyond permissible limits under the Building Code, 2017, the fire safety certificate shall cease to exist and the owner shall apply for approval of Fire Fighting Scheme as per the provisions of section 18.

Above Renewal of Fire Safety Certificate is valid for **Three** year from the date of issue of this letter. Applying for the same well in time shall be the responsibility of owner/occupier.

Also - Renewal of Fire Safety Certificate issued with the condition that the firm shall be liable to install the Water OH as per norms within 03 Months otherwise Fire Safety Certificate deemed Cancelled.



Fire Station Officer

Rewari

Exercising



Digitally signed by Narender Singh
2023.11.06 15:05:40
Reason: Digital Verification